



**OFFICE OF THE DEPUTY FIRE OFFICER
ROURKELA CIRCLE, ROURKELA
Email ID-dforkl-ofs@gov.in**

FORM-V

FIRE SAFETY CERTIFICATE

(See rule-13 (3) of the Odisha Fire Prevention and Fire Safety Rules, 2017)

File No. FSC-45/2023

Certificate No.57 /2023/RKL Circle

Dated- 06.07.2023

This certificate is valid up to 05.07.2025.

(Apply for renewal at least three months before expiry)

Certified that Ghanshyam Hemlata Vidya Mandir, Balijori, At-Debadihi, Po/Dist-Jharsuguda was inspected by officers of Odisha Fire Service in presence of the Principal and it has been found to comply with the Fire Prevention and Fire Safety requirements in accordance with Odisha Fire Prevention and Fire Safety Rules, 2017 and it is fit for occupancy or usage as noted hereunder subject to compliance to the conditions as prescribed herein below:-


1	Ground floor	---Usage---	Educational
2	1 st floor	---Usage---	Educational
3	2 nd floor	---Usage---	Educational


CONDITIONS:-

1. Fire prevention and safety measures and appliances, availability of water supplies and means of access thereto etc. provided in the building or premises, should be maintained by the occupier(s) in best repairs and efficient working condition at all times for use by the occupants or the members of the Fire Service or both in the event of outbreak of fire.
2. The setbacks, driveways, entrance gates, exists, staircases, corridors, and escape ways should not be changed, obstructed or modified in any way.
3. The occupier(s) shall train all staff and occupants periodically to make them well conversant in use and operation of the fire prevention and safety measures.
4. Fire Drills / rehearsals should be organized at least once in six months by involving local fire station.
5. The applicant may comply the additional fire safety provisions in the building if required in future.
6. Photocopies of this Certificate should be framed and displayed at all conspicuous places in all lobbies/corridors in all floors of all towers / blocks of building/ premises.

Memo No-1158 /RKL Circle

Copy to the Principal, Ghanshyam Hemlata Vidya Mandir, Balijori, At-Debadihi, Po/Dist-Jharsuguda for favour of kind information.


**Deputy Fire Officer
Rourkela Circle, Rourkela
Dtd- 06.07.2023**


**Deputy Fire Officer
Rourkela Circle, Rourkela
Deputy Fire Officer
Rourkela Circle, Rourkela**